

WPSAE-PR(18) 20926

A de Blas et al.

## Contribution to safety analyses of DEMO HCPB using AINA code

# Preprint of Paper to be submitted for publication in Fusion Engineering and Design



This work has been carried out within the framework of the EUROfusion Consortium and has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 633053. The views and opinions expressed herein do not necessarily reflect those of the European Commission. This document is intended for publication in the open literature. It is made available on the clear understanding that it may not be further circulated and extracts or references may not be published prior to publication of the original when applicable, or without the consent of the Publications Officer, EUROfusion Programme Management Unit, Culham Science Centre, Abingdon, Oxon, OX14 3DB, UK or e-mail Publications.Officer@euro-fusion.org

Enquiries about Copyright and reproduction should be addressed to the Publications Officer, EUROfusion Programme Management Unit, Culham Science Centre, Abingdon, Oxon, OX14 3DB, UK or e-mail Publications.Officer@euro-fusion.org

The contents of this preprint and all other EUROfusion Preprints, Reports and Conference Papers are available to view online free at http://www.euro-fusionscipub.org. This site has full search facilities and e-mail alert options. In the JET specific papers the diagrams contained within the PDFs on this site are hyperlinked

### Contribution to safety analyses of DEMO HCPB using AINA code

Eduard Baeza<sup>a</sup>, Alfredo de Blas<sup>a</sup>, Albert Riego<sup>a</sup>, Marco Fabbri<sup>a</sup>

#### <sup>a</sup>Fusion Energy Engineering Laboratory, Technical University of Catalonia (UPC) Barcelona-Tech, Barcelona, Spain

The motivation of the current work, framed under the safety EUROfusion activities to develop DEMO, is to present the contribution to the safety studies of the HCPB DEMO carried out by the team tasked with AINA code. During 2016 and 2017 a new AINA version was built in order to evaluate plasma evolution and in-vessel components strains inside the European DEMO designs. As a result, AINA is able to foresee several accident scenarios as plasma disruptions or structural meltings due to LOPCs and in-vessel melt either of FW, blanket and divertor regions because of thermal stresses due to LOCAs. After due analysis, it concludes that BB requires a design review focused on ensuring a suitable operating temperature range with a bigger safety margin. Likewise, it outlines the need to guarantee a quick detection and actuation by means of a proper system, depending on the affected equipment, when the most demanding transients take place. These events may drive the reactor to melting scenarios and very energetic plasma disruptions and include an increase of fueling above 50%, a permanent improvement in the confinement time and a punctual impurity increase above 300%. Other perturbations have been studied, which provide information on non-dangerous cases, impossible situations or melting processes.

Keywords: DEMO, HCPB, AINA, safety analysis, LOPC, LOCA.

#### 1. Introduction

The safety and environmental goals of a fusion power plant design are to protect workers from radiation, electromagnetic fields, chemical and other hazards; the public from radioactive and toxic materials and the environment from pollutants and waste. A conclusion that can be drawn from the historical safety analyses developed for tokamaks is that some of the major risks involve incidents in the vacuum vessel and during the last ten years AINA has become a great tool in order to evaluate plasma evolution and these in-vessel components strains [1-6]. The Blanket is a safety relevant component since its failure could impact the operation of other components, most notably the vacuum vessel. Moreover, the Blanket is credited for some interlock functions such as neutron shielding to the magnets that may affect the dose to the workers during maintenance operations, and hence its design could impact the overall safety of the machine. Thus, this contribution to the HCPB (Helium Cooled Pebble Bed) safety studies is faced to figure out if the in vessel components fulfill the safety functions and to foresee the possible consequences if these functions are not satisfied.

Firstly, it is important to highlight that the tool used to perform this study, AINA 4.0, has been properly validated [7, 8] and the modeled Blanket is the HCPB-2015 v3 [9].

#### 2. Steady State

The steady state scenario used to develop the safety study was presented in the previous AINA team's paper [7] and based on the reference scenario DEMO1 [10]. It is necessary to remember that for the DEMO1 scenario certain functional temperature limits for the HCPB BB (Breeding Blanket) design are slightly exceeded in the worst poloidal region (EUROFER: 563 °C, Beryllium: 677 °C and LiSiO4: 956 °C). These values are slightly different from previous paper ones due to and improvement in the thermal blanket model. Accordingly, it would be advisable to undertake a design review focused on ensuring a suitable operating temperature for materials which make up the blanket [7].

#### 3. Transients

#### 3.1 Types of accidents

Common objective of the FFMEAs (Functional Failure Mode & Effect Analysis) done for the various DEMO systems was, at first, to provide a complete list of potential accident initiating events (IEs). Among those, the Selection of reference accident scenarios for the DEMO plant document [11] has identified 21 PIEs (Postulated Initiating Event) as the most representative for the deterministic assessments to be performed in the first phase of the DEMO design activities both to check the compliance with safety limits and to give rationales for the selection of the reference DEMO reactor model. The vast majority of these 21 PIEs could induce the following load or accident scenarios, which AINA is able to simulate allowing knowledge of their potential impact:

• Plasma disruption or structural material melting due to a LOPC (Loss Of Plasma Control): disruptions represent the highest risk for DEMO integrity and it is assumed that they are only caused by instabilities induced by failures in the systems operating to confine, diagnose and feed the plasma or by accidental events leading to the entrance of undesired elements. By means of AINA, it is possible to identify those failures which lead to the maximum wall damage due to the electromagnetic and thermal load. Likewise, some failures cannot lead the plasma to a disruption event, however this perturbation can affect the plasma physics and damage structural materials. The perturbations that AINA can simulate are failures in the external heating system and in the fuel system, changes in the confinement time and an undesired entrance of impurities.

• In-vessel melt either of FW (First Wall), blanket structure and/or divertor modules because of thermal stresses due to a LOCA (Loos Of Coolant Accident): AINA is able to replicate this phenomena by means of the variation of the coolant mass flow rate through the cooling sections while the reactor is still working.

AINA recreates all these phenomena from the desirable steady state (DEMO1 for this case) and by applying a multiplication factor for modifying the value of the affected variable or parameter at time 0.1 s. Thereupon the code reports on the evolution of other parameters under model constraints presented in the previous AINA team's paper [7].

#### 3.2 Failure in the external heating supply system

An unexpected and instantaneous auxiliary heating cut-off while the HCPB DEMO reactor is operating on DEMO1 steady state causes, as shown in figure 1 and as numerical models presented in the previous AINA team's paper [7] explains, a fast decrease of ion and electron temperatures and a confinement time rise. All of this converges at a new steady state which produces a higher fusion power (P<sub>fus</sub>) of 2420 MW. So, apparently the ignition point has been reached, however the increase of neutronic heat flux (NWL) through the blanket induces the overtaking of the functional temperature limits wider than in the DEMO1 state in less than 10 s (LiSiO4: 1031 °C, Beryllium: 700 °C and EUROFER: 565 °C). For this reason it is necessary to conclude that it is really important to detect rapidly an external power cut-off in order to proceed with a fast plasma shutdown (FPSS) during the first seconds for the purpose of preventing, specifically, LiSiO<sub>4</sub> and Beryllium melting.



Fig. 1. Evolution of relevant variables (ion and electron temperatures, confinement time, fusion power, external power, gain and BB and divertor temperature) when an auxiliary heating cut-off takes place.

An analogous and scaled sequence to the previous one takes place when an unexpected, and instantaneous decrease of auxiliary heating takes place. In short, any auxiliary heating reduction must be detected instantly in order to proceed with a FPSS to avoid the BB collapse.

If the reactor suffers an unexpected, sudden and instantaneous increase of auxiliary heating there are two situations. When the increase is up to a multiplication factor of 6.3 the reactor is driven to an initial and abrupt fusion power increment although it finally decreases rapidly reaching a new state which produces less fusion power than DEMO1 and where the functional temperature limits of the BB materials are closer to the accepted ones. When the increase by a multiplication factor is larger than 6.3 the plasma terminates disruptively due to the beta limit infringement. The higher multiplication factor is, the faster plasma collapse is. At the time of the disruption, the plasma thermal energy (U) (estimated by Paknezhad expression (1) [12] where Z indicates the plasma species,  $n_z$  is the specie density,  $T_z$  is the temperature of the specie and V is the plasma volume) is 1.5 GJ. Consequently the EUROFER limit of 550 °C would be significantly exceeded [13] as well as the rest of the temperature limits.

$$U = \frac{3}{2} \sum_{Z} n_Z T_Z V \tag{1}$$

Nevertheless and in spite of these consequences, it is highly unlikely to reach auxiliary heating as high as those which can lead to this kind of accident due to the installed external power would not exceed 150 MW. Table 1 summarizes some of the key information submitted.

Table 1. Auxiliary heating perturbation summary.

Mult.	Plasma	Mitigation	Consequences
factor	termination		
0	Stabilized	FPSS	P <sub>fus</sub> increase/
			melting
0.5	Stabilized	FPSS	P <sub>fus</sub> increase/
			melting
2	Stabilized	-	$P_{fus}$ decrease
5	Stabilized	-	P <sub>fus</sub> decrease
6.4	Beta limit at	FPSS	Melting by
	88.5 s		excessive U
9	Beta limit at	FPSS	Melting by
	2 s		excessive U

#### **3.3** Failure in the fuel source system

In case fueling is instantly stopped, it is possible to observe how  $P_{fus}$  quickly diminish as well as densities, except the impurities percentages due to physical sputtering driven by the increase in ion and electron temperature. All of this leads to a reduction in BB temperatures reaching acceptable values far below the limits. Unfortunately, a transition L mode is detected after 22.9 s and, finally, plasma collapses at 25.5 s by an overshoot beta limit disruption. Despite this, at the time of the collapse, the U reaches values of up to 0.5 GJ. This released energy could be mitigated by a disruption mitigation system; thereby, the BB would be safeguarded.

An instantaneous fueling reduction leads to a fusion power decrease, specifically half of fueling provides just over half the initial  $P_{fus}$  (from 2037 MW to 1141 MW). The confinement time gets stabilized during the first seconds and material temperatures are greatly reduced even almost below the functional temperature limits. In conclusion, beyond this failure does not cause a dangerous scenario, the new steady state obtained could be a better candidate for DEMO operation from the point of view of temperature limits no exceedance and despite the generation of lower  $P_{fus}$  and, consequently, less gain.

If an unexpected, sudden and instantaneous increase of fueling rate up to 25% a new steady state scenario is reached as in the previous case. However, this one is not positive and several risks are derived from this kind of perturbation. Focusing on transient evolution,  $P_{fus}$  expands as well as confinement time and densities and all of this leads to a scenario where functional temperature limits are widely exceeded in less than 50 s and the melting is unmitigated (LiSiO<sub>4</sub>: 1212 °C, Beryllium: 764 °C and EUROFER: 572.5 °C for a *r*ate up of 25%). Hence, it is essential to be able to guarantee a quick detection and actuation (FPSS) in order to stop the excessive warming.

When an unexpected, sudden and instantaneous increase of fueling rate is above 25%,  $P_{fus}$ , densities and confinement time are continuously growing until a Greenwald limit disruption takes place with a high U (> 1 GJ). The higher fueling rate multiplication factor is, the earlier collapse happens. In short, it is necessary to detect an increase of fueling rapidly and activate FPSS since all these perturbations cause structural damage. Table 2 summarizes some of the key information submitted.

Table 2. Fueling rate perturbation summary.

Mult.	Plasma	Mitigation	Consequences
factor	termination		
0	Beta limit at	Disruption	-
	25.5 s	mitigation	
0.5	Stabilized	_	New and
			better SS
1.25	Stabilized	FPSS	P <sub>fus</sub> increase/
			melting
2	Greenwald	FPSS	Melting by
	limit at 74.7 s		excessive U
6	Greenwald	FPSS	Melting by
	limit at 1.7 s		excessive U

#### 3.4 Variations in the confinement time

Historically, AINA has been used in safety analyses to scan the influence of an increase in confinement time [3, 6, 14] owing to the H mode discovery occurred on 1982. Following this path, the behavior of plasma parameters in case of an increase of confinement time will be simulated.

Instantaneous confinement time improvement produces a fast increase of temperatures as well as densities, which drive to an overall raise of  $P_{fus}$  until plasma terminates disruptively due to the beta limit infringement. U released cause structural damage and melting in any case, hence, it is necessary to detect instantaneously an unexpected variation in confinement

time to conduce the reactor to a FPSS. Table 3 summarizes some of the key information submitted.

Table 3. Confinement time permanent improvement summary.

Mult.	Termination	U	Max P <sub>fus</sub>	Max. LiSiO <sub>4</sub>
factor	time (s)	(GJ)	(MW)	T (°C)
1.5	31.7	2.4	4708	1475
2	5.5	2.4	4905	1432
3	3.7	2.4	5332	1408
5	3	2.4	5565	1388

In contrast, a punctual confinement time variation may happen due to an unexpected behavior during the operation time. The impact of these events is highly dependent on the duration of the confinement time variation and it does not depend so much on the variation factor suffered. Therefore, when the confinement time rises abruptly but decreases after 0.1 s, the effects are not severe since both a multiplication factor of 3 and 10 excites the plasma but the initial steady state is recovered in less than 20 s. During this transition an instantaneous P<sub>fus</sub> peak is reached due to a fast increase plasma temperatures. The BB materials temperatures rise slightly but they are stabilized rapidly. In case the duration of the confinement time variation is longer, the steady state is recovered whilst the perturbation disappears before  $\sim 3$  s where the plasma may collapse due to the Greenwald limit. In these cases and in spite of the recovery, the longer the duration of the perturbation is the grater maximum temperatures are reached and it is highly probable that the reactor suffers a melting situation. Thereby, is necessary to detect an unexpected variation in confinement time.

#### 3.5 Entrance of an undesired quantity of impurities

When the reactor is operating, a flux of particles enter the plasma as impurities due to the erosion phenomena which is inherent to the nature of plasma wall interaction. It can be cause of several undesirable effects as a Plasma Facing Components damage or beneficial effects as shutting down the fusion due to an increase of Bremsstrahlung/line radiation, becoming a passive safety mechanism if a LOCA takes place. So, the consequences of an undesired quantity of impurities must be studied.

A punctual and instantaneous increase of the impurities presence (Xe and W) up to 300% produces a sudden rise of confinement time,  $P_{fus}$ , power losses (Bremsstrahlung and line radiation); a decrease of temperatures and, after a few seconds, the reach of dangerous melting temperatures on the BB materials. A recovery of the initial steady state takes place after 20 s; however, the detection of this perturbation and a FPSS must be fast since the material temperatures rise rapidly.

A punctual and instantaneous increase of the impurities presence (Xe and W) equal to 300% differs from the previous case, the plasma equilibrium is not recovered and plasma skips instantaneous to the L mode where  $P_{fus}$  grows until a peak of 4365 MW. Consequently,

the temperature in the BB rises rapidly (LiSiO<sub>4</sub>: 1395 °C, Be: 771 °C, EUROFER: 572 °C and W: 534.8 °C). Densities are continuously growing until a Greenwald limit disruption takes place at 12 s releasing a U of 1.8 GJ which can damage the reactor structure. So, it is necessary to detect this event rapidly and lead the reactor to a FPSS.

Finally, if an instantaneous increase of the W impurity production takes place,  $P_{fus}$ , densities and confinement time are continuously and slowly growing and depending on the new impurity production rate the plasma may reach a new steady state or it might collapse by means of the Greenwald limit. Nevertheless, any alternative is not instantaneous, so the incident detection must be previous to the endpoint in order to prevent a melting scenario.

#### 3.6 LOCAs

Firstly, it is important to note that AINA's LOCAs are based on the instantaneous variation of the coolant mass flow rate through the cooling sections while the reactor stills working and not after a reactor shut down. From AINA outcomes, it concludes that this kind of failure does not affect the internal plasma conditions but, undoubtedly, even a slight loss of the mass flow (about 30%), leads the reactor to an overall melting scenario rapidly since the material temperatures increase drastically during the first seconds. Specifically, the most demanded area is the LiSiO<sub>4</sub> layer due to its lower thermal conductivity and a big distance from the cooling channel lines, consequently, convection effect is less effective than in other layers. It is indispensable the installation of a quick response system capable of detecting a cooling anomaly rapidly and activating a mitigation action. Figures 2 and 3 show the BB and divertor temperature evolution in function blanket and divertor depth for different LOCA levels. The starting point of this depth is the FW surface of the blanket and the Plasma Facing components surface of the divertor.



Fig. 2. T Evolution of the BB and divertor if a 30% BB and divertor LOCA occurs.



Fig. 3. T Evolution of the BB and divertor if a 60% BB and divertor LOCA occurs.

#### 4. Conclusions

It would be desirable to carry out a possible design review to ensure suitable operating temperatures for all the materials which make up the HCPB BB. Likewise, it would be necessary to guarantee a quick detection and actuation by means of a proper system, depending on the affected equipment when the most demanding transients take place. They may drive the reactor to suffer a melting scenario and a very energetic plasma disruption at the same time. These events include an increase of fueling injection above 50%, a permanent improvement in the confinement time and a punctual impurity increase above 300%. Other perturbations have been studied, which some of them only provide information on non-dangerous cases as a decrease of the fueling injection, impossible situations from a technical point of view as an unexpected increase of external heating above 630% or melting processes as LOCAs or a decrease of the external heating.

Coming from the present study, table 4 summarizes the possible scenarios in order to designers and future safety operators keep an eye on the most dramatic ones.

Table 4. Summary of the possible scenarios.

Consequences	Perturbations	Potential damage level
Melting scenario and a very energetic plasma disruption at the same time and in less than 80 s.	Increase of fueling injection above 50%, a permanent improvement in the confinement time and a punctual impurity increase above 300%.	Very high
A very energetic plasma termination which may discharge a great amount of thermal energy against the walls.	An increase of the external power injection above 630%	High
A melting process.	LOCAs and a decrease or a cut-off of the external power injection, a fueling rate injection increase up to 25%, an occasional variation of confinement time and a punctual impurity increase up to 300%.	Medium
A moderate energetic plasma termination which may discharge a great amount of thermal energy against the walls.	A cut-off of the fueling injection	Low

author's email: eduard.baeza@upc.edu

A new steady state with a fusion	An increase of the external power	_
power decrease	injection between Non- 200% and 630% and a dangerous	3
and lower temperatures.	decrease of the fueling injection rate	

#### 5. Future Work

Future tasks will be focused on DCLL (Dual Coolant Lithium Lead), HCLL (Helium Cooled Lithium Lead) and WCLL (Water Cooled Lithium Lead) contributions to safety analyses using AINA 4.0.

This work has been carried out within the framework of the EUROfusion Consortium and has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 633053. The views and opinions expressed herein do not necessarily reflect those of the European Commission.

#### References

[1] J. Dies, M. Dapena, M. Ramon, J. Garcia, J.C. Rivas, A. Calvo, S. Reyes, AINA safety code, a review of loss of plasma control transients in ITER: sudden increase in fueling rate, sudden increase of auxiliary heating, Fusion Science and Technology. 56 (2009) 31-37.

[2] J.C. Rivas, J. Dies, Upgrading of plasma wall interaction model for tokamak transient modeling code AINA 2.0, used in safety studies of ITER plasma instability events, Fusion Science and Technology. 60 (2011) 825-829.

- [3] J.C. Rivas, J. Dies, Safety studies: Review of loss of plasma control transients in ITER with AINA 3.0 code, Fusion Engineering and Design. 88 (2013) 2709-2713. http://dx.doi.org/10.1016/j.fusengdes.2013.02.134
- [4] J.C. Rivas, J. Dies, ITER safety studies: The effect of two simultaneous perturbations during a LOPC transient, Fusion Engineering and Design. 89 (2014) 2043-2047. http://dx.doi.org/10.1016/j.fusengdes.2014.04.010.
- [5] J.C. Rivas, J. Dies, X. Fajarnés, Revisiting the analysis of passive plasma shutdown during an ex-vessel loss of coolant accident in ITER blanket, Fusion Engineering and Design. 98-99 (2015) 2206-2209. http://dx.doi.org/10.1016/j.fusengdes.2015.06.143
- J.C. Rivas, M. Nakamura, Y. Someya, K. Hoshino, N. [6] Asakura, H. Takase, Y. Miyoshi, H. Utoh, K. Tobita, J. Dies, A. de Blas, A. Riego, M. Fabbri, Safety studies of plasma-wall events with AINA code for Japanese DEMO, Fusion Engineering and Design. (2015). https://dx.doi.org/10.1016/j.fusengdes.2015.10.037
- [7] E. Baeza, A. de Blas, A. Riego, M. Fabbri, Development of the safety code AINA for the European DEMO designs, Fusion Engineering and Design. (2018).https://doi.org/10.1016/j.fusengdes.2018.04.074.
- [8] M. Fabbri, A. de Blas, A. Riego, I. Zamora, E. Baeza, Methodology for the improvement of the AINA Code wallmodel applied to DEMO WCPB blanket, Fusion Engineering and Design, ISSN 0920-3796, (2017). http://dx.doi.org/10.1016/j.fusengdes.2017.05.027

- [9] F.A. Hernández, Q. Kang, B. Kiss, P. Norajitra, G. Nádasi, P. Pereslavtsev, C. Zeile, HCPB Design Report 2015. Internal Deliverable BB-1.2.1-T002, (EUROfusion document, Working Package of Safety and Environment).
- [10] R. Wenninger, DEMO1 Reference Design 2015 April ("EU DEMO1 2015"), 2MDKFH. (EUROfusion document, Working Package of Safety and Environment).
- [11] T. Pinna, Selection of reference accident scenarios for the DEMO plant. 2MA6TU v1 0, (EUROfusion document, Working Package of Safety and Environment).
- [12] A. Paknezhad, A.S. Elahi, M. Ghoranneviss, Plasma Thermal Energy Measurement based on the Plasma Diamagnetic Effect in the IR-T1 Tokamak, 3 (2013) 145-148. doi:10.5923/j.jnpp.20130305.04.
- [13] R. Wenninger et al. The DEMO wall load challenge, Nuclear Fusion. 57 (2017) 046002. doi:10.1088/1741-4326/aa4fb4.R.
- [14] J.C. Rivas, Development of AINA code for the study of loss of plasma control events in ITER and DEMO, and contribution to the systems study of DEMO, PhD thesis, Universitat Politècnica de Catalunya, 2016.